

**Egerton Millennium Hall
Plan (not to scale)**

Fire Exits
Or
1mt from hall

marquees should not be more than 7mt x 15mt
and must have 2 fire exits opposite the fire exits
from the main hall or 1mt away from any walls,
marquees on the rear hard standing must have a
fire exit opposite the corridor fire exit or be 1mt
away from any walls

